

校准证书

CALIBRATION CERTIFICATE

证书编号: [2019DW00860682]

Certificate No.

委托方名称 Customer	中广核太阳能德令哈有限公司
委托方地址 Address	青海省海西州德令哈市西出口315国道以北
样品名称 Name Of Sample	发电机转子交流阻抗测试仪
制造厂商 Manufacturer	武汉国电华美电气设备有限公司
型号规格 Model/Type	HM5009
器具编号 No Of Sample	1911065

证书专用章
Stamp



校准日期 Calibration date	2019 年 12 月 19 日 Y M D
--------------------------	---------------------------

证书批准人 Approved by	耿睿
核验员 Checked by	李艳
校准员 Calibrated by	尹伟

本次校准所使用的测量装置均溯源至保存在中国计量科学研究院的国家计量基准。中国计量科学研究院于1999年代表中国签署了国际间“国家计量基准及国家计量研究院出具的校准和测量证书相互承认协议”。

The measuring equipment used in the calibration is traceable to national primary standards maintained in National Institute of Metrology (NIM). NIM is the signatory to the Mutual Recognition Arrangement (MRA) for national measurement standards and for calibration and measurement certificates issued by national metrology institutes.



● 本院是政府计量行政管理部门依法设立的法定计量检定机构

This laboratory is a legal metrological verification institution established by the government metrological administrative department according to law.

● 本院质量管理体系符合ISO/IEC17025标准的要求。

The quality management system for laboratory complies with ISO/IEC 17025 standards.

● 本次校准的技术依据(名称、代号)

Reference documents for the Calibration (Name、Code)

参照: JJF 1587-2016 数字多用表校准规范

● 本次校准所使用的主要计量标准器具

Main standards of measurement used in the Calibration

设备名称

Name of Equipment

交直流标准表

型号/编号

Model/Serial No.

9080A/015

证书号/有效期

Certificate No./Due Date

校准字

第201910000498号/2020-10-08

● 校准环境条件

Environmental condition on the Calibration

温度: 20.2°C

Temperature

相对湿度: 33 %

R.H.

其它: ---

Others

气压: ---

Pressure

地点: 本院光谷基地B102

Place

原始记录编号: 2019DW00860682

Record No.

本校准结论, 仅对受校样品的本次校准有效。

It's Effect That Results of This Report Relate Only To The Sample(s) Calibrated.

未经本院许可, 不得部分复制本证书。

校准数据/结果

Data/Results of Calibration

电压	
显示值 (V)	实际值 (V)
99.98	100.00
199.9	200.0
299.9	300.0
399.8	400.0
499.8	500.0
电流	
显示值 (A)	实际值 (A)
500.0mA	500.0mA
1.000	1.000
2.003	2.000
5.014	5.000
10.02	10.00
20.05	20.00
测量不确定度	电压、电流: $U_{rel}=0.1\%$, $k=2$

以下空白

